



# ORION™

LIMITED USE / LIMITED APPLICATION ELEVATOR

## **Planning Guide**

Limited Use / Limited Application Elevator

### **Applicable Codes:**

ASME A17.1 - 2004 Section 5.2

CAN/CSA B44 - 04

Effective September 1, 2006

Revised May 22, 2008

# TABLE OF CONTENTS

<b>GENERAL</b>	<b>3</b>
<b>PRODUCT DESCRIPTION</b>	<b>4</b>
<b>ORION LU/LA ELEVATOR SPECIFICATIONS</b>	<b>5</b>
<b>CAB TYPE SELECTION SHEET</b>	<b>6</b>
<b>MACHINE ROOM OPTIONS</b>	<b>7</b>
<b>HOISTWAY AND PIT ELECTRICAL NOTES</b>	<b>8</b>
<b>CONTROLLER TANK SPECIFICATIONS</b>	<b>9</b>
<b>ORION 48" X 54" TYPE 1 WITH 2 SPEED DOORS</b>	<b>10</b>
<b>ORION 48" X 54" TYPE 2 WITH 2 SPEED DOORS</b>	<b>11</b>
<b>ORION 48" X 54" TYPE 3 (4) WITH 2 SPEED DOORS</b>	<b>12</b>
<b>ORION 42" X 60" TYPE 1 WITH 2 SPEED DOORS</b>	<b>13</b>
<b>ORION 42" X 60" TYPE 2 WITH 2 SPEED DOORS</b>	<b>14</b>
<b>ORION 48" X 54" TYPE 1 WITH SWING DOORS</b>	<b>15</b>
<b>ORION 48" X 54" TYPE 2 WITH SWING DOORS</b>	<b>16</b>
<b>LOADS ON BUILDING</b>	<b>17</b>
<b>ENTRANCE MOUNTING DETAILS FOR 2 SPEED DOORS WITH DRYWALL</b>	<b>18</b>
<b>ENTRANCE MOUNTING DETAILS FOR 2 SPEED DOORS WITH DRYWALL CONSTRUCTION</b>	<b>19</b>
<b>ENTRANCE MOUNTING DETAILS FOR 2 SPEED DOORS WITH MASONRY CONSTRUCTION</b>	<b>20</b>
<b>ENTRANCE MOUNTING DETAILS FOR 2 SPEED DOORS WITH MASONRY CONSTRUCTION</b>	<b>21</b>
<b>2 SPEED AUTOMATIC DOOR AND GUIDE RAIL INFORMATION</b>	<b>22</b>
<b>PIT AND OVERHEAD CLEARANCE DETAILS</b>	<b>23</b>
<b>ORION STANDARD NOTES</b>	<b>24</b>
<b>SPECIFICATIONS FOR PART 5.3 COMPLIANCE</b>	<b>25</b>

# GENERAL

This planning guide is designed to assist architects, contractors and lift professionals in planning for a Orion Elevator to meet the requirements of ASME A17.1 - 2004 Section 5.2 and CAN/CSA B44 - 04.

This unique elevator is designed to help solve accessibility problems in commercial buildings and meet state and national codes covering the Limited Use/Limited Application (LULA) elevators.

We strongly recommend you contact the Authority Having Jurisdiction (AHJ) in the region where the equipment will be installed. Become familiar with all requirements governing the installation and use of elevators in public and private buildings. It is extremely important for you to know and adhere to all regulations concerning installation and use of elevators.

## IMPORTANT NOTICE


This Planning Guide provides nominal dimensions and specifications useful for the INITIAL planning of an elevator project. BEFORE beginning actual construction, be sure to receive application drawings customized with specifications and dimensions for your specific project.

Lift configurations and dimensions are in accordance with our interpretation of the standards set forth by AASME A17.1 - 2004 Section 5.2 and CAN/CSA B44 - 04. Please consult Savaria Concord Lifts Inc. or the authorized Savaria Concord dealer in your area for more specific information pertaining to your project, including any discrepancy between referenced standards and those of any local codes or laws (AHJ).

The dimensions and specifications in this Planning Guide are subject to change (without notice) due to product enhancements and continually evolving codes and product applications.

- Determine customer's intention for use.
- Determine code requirements of site.
- Determine installation parameters of site.
- Use page 6 to determine the car type and hoistway size requirements.
- Use pages 7 and 24 to plan for machine room and electrical requirements.

# PRODUCT DESCRIPTION



**Orion in Hoistway**

## **Meets (ADA) Americans with Disabilities Act Requirements**

The Orion meets the requirements of the ADA Accessibility Guidelines as a means to provide public building access.


## **Design Assistance**

With over 30 years of experience, Savaria Concord has the expertise to provide solutions to practically every design challenge you face. Please call our Customer Service Department for professional advice at (800)661-5112 or (905)791-5555.


# ORION LU/LA ELEVATOR SPECIFICATIONS

Load Capacity	1400 lb (635 kg)
Rated Speed	30 fpm (0.15 mps)
Power Supply (circuit to be supplied by others)	208 volt, three phase, 30 amps, 60 Hz or 230 volt, single phase, 50 amps, 60 Hz
Lighting Supply (circuit to be supplied by others)	115 volt, 60 cycle, 15 amps
Drive System	1:2 Cable Hydraulic with Slack Cable Safety Device 5 hp submersed motor Two 3/8" diameter steel aircraft cables Rope wedge sockets
Cab Size	W48" x 54" x H84" (1219 mm x 1371 mm x 2134 mm), Type 1, 2, 3, 4 W42" x L60" x H84" (1067 mm x 1524 mm x 2134 mm), Type 1, 2, 3, 4 W51" x L51" x H84" (1295 mm x 1295 mm x 2134 mm), Type 1, 2, 3, 4
Cab Panel Finish	Steel Panel Cab with Optional Laminates
Maximum Travel	18 inches (457 mm) to 25 feet (7.6 m) ANSI, up to 40 feet Residential and CSA
Control System	Automatic User Interface Programmable Logic Controller (PLC)
Levels and Openings	4 Stops and 2 Openings per Level
Pit Depth Required	14 inches (355 mm) minimum up to 96 inches (2438 mm)
Minimum Overhead Clearance	120 inches (3048 mm) for Existing Construction, 134 inches (3404 mm) for New Construction
Hall Station and Control Panel Finish	Rectangular Stainless Steel (standard) or Brass (optional)
Standard Features	8 lb/ ft or 16 lb/ft T-Rail System Anti-Creep Device Architectural White Ceiling Automatic Cab ON/OFF Lighting Car Top Stop Switch and Car Top Prop (where required) Data Plates, Capacity Tags and Rope Tags Digital Floor and Directional Indicator Emergency Manual Lowering, Stop Key Switch and Alarm Buttons Emergency Battery Back-up for Lighting, Alarm and Emergency Lowering Floor Specific Battery Lowering Illuminated Cab Operating Buttons Limited Warranty covers the repair or replacement of any defective parts for a period of 36 months from date of shipment Magnetic Floor Selection, Stopping and Re-leveling Manual Reset Slack Rope Safety Switch Maintenance Pit Props Pit Switch Pit Clearance Switch Presentation Drawings Pump Run Timer Rail Sections (8 ft standard or 16 ft optional) Recessed Incadescent Down Lights in Stainless Steel or Brass Color Recessed Plywood Floor Two 12 V, 4 AH, Sealed No Maintenance Batteries with 24 V, 4 amp Smart Charge™ Battery Charge Variable Speed Pressure Compensated Valve with Manual Lowering Upper and Lower Terminal Limits
Options	2 Speed Sliding Doors for Drywall or Masonry Hoistway Finish 15 ft, 20 ft, or 25 ft Hose with Flow Control 90 degree Entry/Exit Cab Automatic Cab Gate Operator and Automatic Hoistway Door Operator Automatic Home Landing to Pre-Selected Floor Brass COP, Hall Call Stations, Handrail and Recessed Down Lights Buffer Springs, 15" (381 mm) minimum Pit Depth Required Conductor Cable for Hoistway to Pump Wiring, 40 ft (12.19 m), 60 ft (18.29 m) or 80ft (24.38 m) Fire Rated Manual or Automatic Swing Doors with Automatic or Manual Accordion Style Cab Gates Firefighter Service - Phase 1 and 2 Flow Control, Overspeed Valve and Pipe Rupture Valve Hands-Free Telephone Overspeed Governor Raised Plastic Laminated Panels in a Choice of 7 Colors Recessed Stainless Steel or Brass Telephone Cabinet


# CAB TYPE SELECTION SHEET




TYPE 1R




TYPE 1L




TYPE 2




TYPE 3




TYPE 4



Type 1



Type 2







Type 3 and 4

## IMPORTANT

Finished hoistway dimensions must include the drywall. Determine the fire rating of the hoistway, the type and layers of sheet rock and build only off the final shop drawings specific to your project.

# MACHINE ROOM OPTIONS



Machine room must be built in accordance with elevator manufacturer and applicable building codes and regulations. Adequate ventilation is required to maintain a temperature of 50° to 100°F for output of 3600 BTU per hour.

A convenience outlet, 115 VAC 15 AMP single phase with G.F.I. shall be located next to the light switch in the machine room. Provided and installed by others.

Provide lockable, in open position, fused disconnect switches located adjacent to the elevator controller. Fusing must be selectively coordinated. Fuse either 208V Three Phase w/30 AMP or 230V Single Phase w/50 AMP service, fuse 115V for 15 AMP service for cab lighting. (Must comply with applicable codes.)

The electrical circuit provided shall be either 30 AMP, 208V three phase or 50 AMP 230V single phase, dedicated circuit with equipment ground. The circuit shall terminate on the line side terminal lugs of the disconnect. The electrical circuit is provided and installed by others.

Disconnect switch to have auxiliary normally open interlock switch. Interlock equal to Square D EK-300-Z.

30" wide x 36" deep work space required in front of the Disconnects and the Elevator Controller.

Machine room lighting shall be a minimum of 19 foot candles at working surfaces. The switch for the light must be within 18" of the strike side of the machine room door. The light must be guarded to prevent accidental breakage or contact with the hot bulb. The switch, light, wiring, and guard are provided and installed by others.

A telephone line circuit is to be provided and installed by others. This circuit shall be brought to the machine room controller in conduit. This circuit must be connected to a dedicated outside line or a 24 hour central exchange.

The elevator controller/pump unit dimensions - 27.5" wide x 62.8" high x 16.15" deep with 39" clear space in front

Machine room access door must be self closing, self locking, key locked and have a spring return latch.

Consult local building codes for door construction. The door and hardware are both provided and installed by others.

Machine room is required to be free of all pipes, wiring and obstructions not related to the operation of the elevator. Provide a 4 inch conduit from the lift shaft to the remote machine room.

# HOISTWAY AND PIT ELECTRICAL NOTES

A load bearing wall is required to sustain rail reactions. See page 17 for rail reactions.

Suggested hoistway pit floor construction consists of an 8" (203 mm) concrete slab poured on a natural or compacted soil with a minimum allowable bearing pressure of 1.0 KSF.

The minimum compressive strength of the concrete at 28 days must be no less than 3000 PSI. #5 reinforcing steel (grade 60) must be placed at the bottom of the slab in 2 traverse directions and at a spacing of 12" (305 mm).

Hoistway pit floor to support a load of 10 kips (10,000 lbs)/44.48KN (includes impact).

**120" (3048 mm) overhead clearance** required above the top landing floor with top prop (**existing construction**).


**134" (3404 mm) overhead clearance** required above the top landing floor without top prop (**new construction**).

14" (356 mm) minimum pit. (A Clearance Device is provided to attain required 36" (914 mm) refuge space).

Hoistway sizes reflect running and access clearances only. Consult your local AHJ to assure compliance with local codes.

Hoistway is required to be free of all pipes, wiring and obstructions not related to the operation of the elevator.

If a Dedicated Pit Light is required by your local AHJ, please follow the guidelines below for accommodating this in your hoistway



# CONTROLLER TANK SPECIFICATIONS


Dimensions (inches)	H 63" x W 28" x D 17" (approx.)
Minimum Required Clearance in Front (inches)	39"
Valve and Manual Lowering Handle Location	Inside Tank
Rupture Valve Test	T-fitting factory installed
Tank to Controller Wiring	Quick connect valve and motor wiring
Controller Layout	PLC
Keyed Lock to Tank	Yes
Machine Room Required	Yes
Tank Capacity (gal/ltr)	15-16.5 gal/57-63 ltr
Max. Dry Weight (lbs/kgs)	147 lbs/55 kg
Max. Filled Weight (lbs/kgs)	312 lbs/117 kg
Operating Environment	50°F - 120°F /10°C - 49°C
Operating Volume	57 dBA

## Controller Tank Features

Hydraulic Hose Connection Ports on either side of the tank

Built in handles on either side of the tank


Isolation mounting of pump motor valve assembly minimizes operating noise




**PLC Controller Tank**

# ORION 48" X 54" TYPE 1 WITH 2 SPEED DOORS

Type 1



Finished hoistway dimensions must include the drywall (where applicable). Determine the fire rating of the hoistway, the type and layers of sheet rock. Build only from shop drawings specific to your project.




## NOTE

**Plan view drawing can be reversed for Right Hand applications.**


# ORION 48" X 54" TYPE 2 WITH 2 SPEED DOORS

Type 2



Finished hoistway dimensions must include the drywall (where applicable). Determine the fire rating of the hoistway, the type and layers of sheet rock. Build only from shop drawings specific to your project.


**For Metric Equivalents**  
 Multiply Inches times 25.4 for mm  
**Example:**  
 40.25" x 25.4 = 1022.35 mm



# ORION 51" X 51" TYPE 3 (4) WITH 2 SPEED DOORS


Type 3 or 4

Finished hoistway dimensions must include the drywall (where applicable). Determine the fire rating of the hoistway, the type and layers of sheet rock. Build only from shop drawings specific to your project.



**For Metric Equivalents**  
 Multiply Inches times 25.4 for mm

**Example:**  
 40.25" x 25.4 = 1022.35 mm




For Masonry or Drywall Entrance Details, refer to drawings on pages 18-21

**NOTE**

**Plan view drawing can be reversed for Type 4 applications.**


# ORION 42" X 60" TYPE 1 WITH 2 SPEED DOORS

Type 1



Finished hoistway dimensions must include the drywall (where applicable). Determine the fire rating of the hoistway, the type and layers of sheet rock. Build only from shop drawings specific to your project.

**For Metric Equivalents**  
 Multiply Inches times 25.4 for mm  
**Example:**  
 40.25" x 25.4 = 1022.35 mm




**NOTE**

**Plan view drawing can be reversed for Right Hand applications.**


# ORION 42" X 60" TYPE 2 WITH 2 SPEED DOORS

Type 2

Finished hoistway dimensions must include the drywall (where applicable). Determine the fire rating of the hoistway, the type and layers of sheet rock. Build only from shop drawings specific to your project.




**For Metric Equivalents**  
 Multiply Inches times 25.4 for mm  
**Example:**  
 40.25" x 25.4 = 1022.35 mm




# ORION 48" X 54" TYPE 1 WITH SWING DOORS

Type 1



Finished hoistway dimensions must include the drywall (where applicable). Determine the fire rating of the hoistway, the type and layers of sheet rock. Build only from shop drawings specific to your project.




## NOTE


**Plan view drawing can be reversed for Right Hand applications.**




# LOADS ON BUILDING



Rail reactions do not include safety factors. Applicable safety factors must be considered in hoistway design.






**Rail Bracket Dimensions**



**Support Wall Rail Orientation**



# ENTRANCE MOUNTING DETAILS FOR 2 SPEED DOORS WITH DRYWALL CONSTRUCTION




**Contractor please note:  
Grouting at the sill may be required after the door frames are set.**

# ENTRANCE MOUNTING DETAILS FOR 2 SPEED DOORS WITH MASONRY CONSTRUCTION

**For Metric Equivalents**  
Multiply Inches times 25.4 for mm




**Example:**  
40.25" x 25.4 = 1022.35 mm



TYPICAL SECTION


(SILL ASSEMBLY FOR CONCRETE IS SHOWN)

# ENTRANCE MOUNTING DETAILS FOR 2 SPEED DOORS WITH MASONRY CONSTRUCTION




**Contractor please note:  
Grouting at the sill may be required after the door frames are set.**

# 2 SPEED AUTOMATIC DOOR AND GUIDE RAIL INFORMATION




**Door Frame Elevation**



**For Metric Equivalents**  
 Multiply Inches times 25.4 for mm

**Example:**  
 $40.25" \times 25.4 = 1022.35 \text{ mm}$




**Rails and Sling in Hoistway**


**Notes:**

1. See hoistway requirements for the location of the door centerline.
2. Door panels and frame are primed for painting.

# PIT AND OVERHEAD CLEARANCE DETAILS



A minimum pit depth of 14" is required.



# ORION STANDARD NOTES

## HOISTWAY

The hoistway must be designed and built in accordance with "safety code for elevators and escalators" (ASME A17.1) and all state and local codes.

Due to close running clearances owner/agent must ensure that hoistway and pit (where provided) are level, plumb and square and are in accordance with the dimensions on these drawings.

## MINIMUM OVERHEAD CLEARANCE

Owner/agent must ensure minimum overhead clearance is in compliance with codes.

## CONSTRUCTION SITE

Owner/agent to provide all masonry, carpentry and drywall work as required and shall patch and make good (including finish painting) all areas where walls/floors may require to be cut, drilled or altered in any way to permit the proper installation of the lift.

## DIMENSIONS

Contractor/customer to verify all dimensions and report any discrepancies to our office immediately.

## STRUCTURAL

Structural engineer to assure that building and shaft will safely support all loads imposed by the lift equipment. Refer to the tables on installation drawings for loads imposed by the equipment.

Suitable lintels must be provided by owner/agent. Door frames are not designed to support overhead wall loads.

## ELECTRICAL

Power supply with a lockable fused disconnect and auxiliary contact to brake the battery feed, or circuit breakers with a 3-pole breaker for battery feed required in compliance with electrical code (contact your Savaria Concord dealer or refer to the table below for OEM part numbers.

Disconnect Switch Types & Accessories	Cutler Hammer	Federal Pioneer	Siemens
<b>1 PHASE 5 H.P. Pump Unit</b>			
<b>2 Pole Solid Neutral 208 or 230V 1 PH</b>	1HD222N	1622SN	ID322
<b>Required Auxiliary Contact</b>	DS16CP	E1K-1AEV-W94	MSSAK 116
<b>Required Type "D" Fuse (Buss type "FRN" or equal)</b>	2@50 amp	2@50 amp	2@50 amp
<b>3 PHASE 5 H.P. Pump Unit</b>			
<b>3 Pole Solid Neutral 208V 3 PH</b>	1HD321N	1332SN	ID321
<b>Required Auxiliary Contact</b>	DS16CP	E1K-1AEV-W94	MSSAK 116
<b>Required Type "D" Fuse (Buss type "FRN" or equal)</b>	3@30 amp	3@30 amp	3@30 amp
<b>Cab Lighting</b>			
<b>1 Pole Solid Neutral 120V 1 PH</b>	GP 111N	86211	CFN 211
<b>Required Type "D" Fuse (Buss type "T" or equal)</b>	1@15 amp	1@15 amp	1@15 amp

Permanent power of 230V 1ph 50 amp or 208V 3ph 30 amp must be supplied by others before installation.

Remote hall call (when supplied) to be installed by the owner/agent at 42" from landing floor.

## ENTRANCES

Entrance assemblies must be adjusted to align with platform and interlock equipment. Others to allow an adequate rough opening.

Entrance assembly must be securely fastened to walls by elevator contractor.

# SPECIFICATIONS FOR PART 5.3 COMPLIANCE

## PART 1 GENERAL

### 1.01 SUMMARY

A. The product described herein, manufactured by Savaria Concord Lifts Inc, is an elevator designed and dimensioned to provide Limited Use/Limited Application (LULA) elevator to suit individual building requirements for use by persons with disabilities.

### 1.2 REFERENCES

- A. Elevator shall be designed, manufactured and installed in accordance with the following standards:
1. American National Standards Institute (ANSI).
  2. American Society of Mechanical Engineers (ASME).
  3. National Electrical Code (NEC)  
Canadian Electrical Code (CEC)
  4. American Society for Testing Materials (ASTM).
  5. American Welding Society (AWS).  
Canadian Welding Bureau (CWB)

### 1.3 SYSTEM DESCRIPTION

- A. 5 hp submersed motor and pump with electronic proportional valve assembly; Programmable logic controller with collective operation; 1:2 roped hydraulic single stage cylinder with line rupture valve.
- B. Number of Stops: (specify:) Two to Four.
- C. Car Configuration: (specify:) straight-thru, 90° side exit or enter/exit same side.
- D. Maximum Travel: (specify:) Up to 25' (7.62 m)
- E. Rated Load: (specify:) 1400 lbs. (635 kg)
- F. Rated Speed: 30 fpm (.15m/s)
- G. Car Size:
1. 48" x 54" (1219 mm x 1372 mm) platform (standard)
  2. 84" (2134 mm) high ceiling
- H. Car Walls: (specify:) Steel panels (black or architectural white) with (optional) raised plastic laminate panels (contact Savaria Concord for colors).
- I. Car Ceiling: White panel.
- J. Car Lighting: Four recessed lights.
- K. Operating Features:
1. Car Operating Panel: (specify:) Brushed stainless steel or brushed brass panel with illuminated automatic controls, keyed light switch, emergency stop switch and alarm button
  2. Hall Stations: (specify:) Brushed stainless steel or brushed brass panel with illuminated button and (specify option:) key lock provided at each landing.
  3. Car Door(s): Fully automatic, side opening, sliding car door with electromechanical interlocks, obstruction sensor, and automatic re-open system.
  4. Hoistway Doors: 1 ½ hour fire rated fully automatic side opening, sliding hoistway doors with two side opening panels in steel frame with electromechanical interlocks.
  5. Handrail: (specify:) Stainless steel or brass.
  6. Pit Switch

7. Car top inspection station with UP and DOWN test switches, emergency stop, light outlet
8. Automatic homing to the lowest floor (optional)
9. Slack rope safety.
10. Anti-creep device.
11. Overspeed governor (may not be required) – consult AHJ
12. Dual direction leveling.
  - Upper and lower terminal limit.
  - Pump run timer.
  - Pit clearance device (where required)
  - Automatic battery powered and manual emergency lowering control devices.
  - Minimum pressure switch.
  - Maintenance stop blocks.
  - (specify option:) Fire Fighters Service (available).
  - (specify option:) Hall lanterns with chime.
  - (specify option:) Recessed telephone cabinet (brushed stainless steel or brushed brass).
  - (specify option:) Buffer springs (requires 24" pit).

### 1.4 QUALITY ASSURANCE

- A. Manufacturer: Provide elevator manufactured by a firm with a minimum of 10 years experience in fabrication of elevators equivalent to those specified.
- B. All designs, clearances, workmanship and material, unless specifically accepted, shall be in accordance with all codes having legal jurisdiction.
- C. All load ratings and safety factors shall meet or exceed those specified by all governing agencies with jurisdiction and shall be certified by a professional engineer.
- D. Elevator shall be subject to applicable state, local and city approval prior to installation and subject to inspection after installation. Determination of and adherence to these regulations is the responsibility of the elevator contractor.
- E. Welders certified in accordance with requirements of AWS D1.1 or CWB shall perform all welding of all parts.
- F. Substitutions: No substitutions permitted.

### 1.5 WARRANTY

- A. Warranty: Manufacturer shall warrant component parts of the Orion elevator for a period of 36 months from shipping date. This warranty only applies to products installed and maintained by a Savaria Concord Authorized Dealer in conformance with all applicable local and national codes. The warranty is void if regular inspection and maintenance of product is not being carried out by an Authorized Savaria Concord Dealer in accordance with the recommendations contained in the Owner's Manual. It is the Owner's responsibility to keep records of all such service.

## PART 2 PRODUCT

### 2.1 MANUFACTURER

Provide the Orion Commercial LU/LA Elevator manufactured by Savaria Concord Lifts Inc.  
Toll Free Number (800) 661-5112  
Phone (905) 791-5555  
Fax (905) 791-2222  
Email: [info@concordelevator.com](mailto:info@concordelevator.com)  
Web site: <http://www.concordelevator.com>

### 2.2 MATERIAL

- Guide Rail: Dual 8 lbs./ft. machined steel T-rail system.
- Wire Rope: Two 3/8" diameter 7 x 19 ga. IWRC aircraft cables with rope wedge sockets.
- Sling: Structural and formed steel plates with guide shoes.
- Platform Floor: Unfinished plywood flooring.

### 2.3 FINISHES

- A. Components shall be prepared with
- 1) pre-treatment,
  - 2) alkaline detergent wash,
  - 3) clear water rinse,
  - 4) iron phosphate coating,
  - 5) clear water rinse and finished with electrostatically applied and baked thermostatic powder coat finish. Standard color is architectural white.

### 2.4 ELECTRICAL SYSTEMS

- A. The electrical contractors shall provide:
1. 208V three phase 30 AMP 60 Hz or 230 V single phase 50 AMP 60 Hz source in the machine area with manually operated fused line disconnect.
  2. 115 VAC, single phase, 15 amp, 60 Hz, single phase power source with manually operated fused line disconnect for car lighting and a light outlet inside the hoistway.
  3. Telephone circuit in the machine area.

## PART 3 EXECUTION

### 3.1 ACCEPTABLE INSTALLERS

- A. Installers shall be experienced in performing work of this section who have specialized in work comparable to that required for this project.
- B. Installers shall be certified and trained by the manufacturer.

### 3.2 EXAMINATION

- A. Use field dimensions and approved manufacturer's shop drawings to examine substrates, supports and other conditions under which this work is to be performed. Do not proceed with work until unsatisfactory conditions are corrected.

### 3.3 INSTALLATION

- A. The Orion elevator shall be installed in accordance with manufacturer's instructions and as specified and approved by architect.

### 3.4 DEMONSTRATION

- A. The elevator contractor shall make a final check of the elevator's operation with the Owner or Owner's representative present prior to turning the elevator over for use. The elevator contractor shall determine that operating and safety devices are functioning properly.

### END OF SECTION

Intent of specification is to broadly outline equipment required but does not cover details of design and construction. Dimensions and specifications are subject to constant change and continually evolving codes and product applications. For additional technical information, contact Savaria Concord Lifts Inc. at (800) 661-5112 or [www.concordelevator.com](http://www.concordelevator.com).



## Savaria Concord Lifts Inc.

107 Alfred Kuehne Blvd.  
Brampton, ON L6T 4K3  
Phone: 905-791-5555  
Fax: 905-791-2222  
Sales: 800-661-5112

email: [info@concordelevator.com](mailto:info@concordelevator.com)  
[www.concordelevator.com](http://www.concordelevator.com)